



10557 Metric Drive • Dallas, Texas 75243  
Toll Free: (800) 323-2439 • Phone: (214) 340-0265 • (Fax) 214-340-5870



## Product Change Notice September 18, 2023

**Products Affected:** OA254EC ATEX Series  
**Type of Change:** Change of product certification on specific models  
**Reason for Change:** Change in product design certification criteria  
**Affected Models:** OA254EC-UR-1TBIP68A, OA254EC-11-1TBXCIP68A,  
OA254EC-22-1TBXCIP68A

### Discussion:

During testing to obtain ATEX certification for the affected models, UL Laboratories notified Orion Fans that they would no longer provide ATEX certification for fan models that used the industry-standard fan terminal connection. UL Laboratories stated that they would grant ATEX certification only for fan products using a wire lead power connection. Because ATEX certification was not granted on the terminal products, the affected products were relabeled to remove reference to the ATEX certification and will be produced and sold as standard IP68 products. Customers who require ATEX certified OA254EC fan products must buy the following part numbers that did receive certification: OA254EC-UR-1WBIP68A, OA254EC-11-1WBXCIP68A, and OA254EC-22-1WBXCIP68A.

### Part Number Change Table:

Original Part Number	New Part Number without ATEX certification
OA254EC-UR-1TBIP68A	OA254EC-UR-1TBIP68
OA254EC-11-1TBXCIP68A	OA254EC-11-1TBXCIP68
OA254EC-22-1TBXCIP68A	OA254EC-22-1TBXCIP68